



TEST REPORT

Issued to : M/s. Avisan Properties Sarabha Temple Backside, Sainikpuri, Hyderabad.		Registration No.:	LL/20-21/0067/03.
		Sample Receipt Date:	02.07.2021
		Report issue date:	03.07.2021
Analysis Starting Date:	02.07.2021	Quantity Received:	1 L x 1 No. in plastic bottle
Analysis Completion Date:	03.07.2021	Sample condition on Receipt:	Good
Sample Particulars: Borewell water			

TEST RESULTS

S. No.	Parameter	UOM	Test Method	Requirements as per IS 10500:2013	Result
1.	Total Hardness as CaCO ₃	mg/l	2340 G, APHA 23.1 Edition 2017	250	398.2

UOM: Unit Of Measurement

Note: The above results relate only to the sample tested.


K. Narasimha
Charist

*****END OF THE REPORT*****

